

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7167-1615:100

Page 1 of 2

**CATEGORY:** Control Unit (Household)

**LISTEE:** Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450  
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

**DESIGN:** Model D7212G and \*D7212GV2 residential fire alarm control unit. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

D720/1255/1256/1257/1260	Command Centers (may be followed by W or R)
D113	Battery Supervision Module
D122/122L	Dual Battery Harness
D125B	Powered Loop Interface Module
D126	12V, 7Ah Battery
D1218	12V, 17.2 Ah or 18 Ah Battery
D127	Relay
D129	Initiating Circuit Module
D130	Relay Module
D136	Plug-In Module
D8121A/8122	Subscriber Terminal Unit
D8125/8125MUX	POPEX Module
D9127T/9127U	POPIT Module
D8128D	OctoPOPIT Module
D9133TTL-E/DX4020	Network Interface Module
D192C/192G	Circuit Supervision Module
D1640	Transformer
D8004/8103/8109/8108A	Enclosures
D8129	OctoRelay Module
D8130	Release Module
D8132	Battery Charger Module
D9131A	Printer Interface

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as a household fire alarm control unit for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

For fire alarm use, the secondary (standby) power supply shall supply energy during power loss to operate a protected premises, central station, or proprietary system for 24 hours or an auxilliary or remote station system for 60 hours in the normal condition followed by not less than 5 minutes of alarm as required by code.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

**NOTE:**

- 1) For household system, **Fire Alarm Verification Feature** (delay of fire alarm signal) is NOT approved for use in California. This feature shall not be programmed into the unit.
- 2) Burglary and other non-fire functions were not examined.

\*Rev. 09-29-2005 jew



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By:

**BEN HO**, Chief  
Fire Engineering Division